

Notice

Environmental Protection Act 1994

Notice of decision - Temporary emissions licence

This statutory notice is issued by the administering authority pursuant to section 357E of the Environmental Protection Act 1994, to advise you of a decision or action.

To: Central SEQ Distributor – Retailer Authority T/A
Queensland Urban Utilities
Level 2, 15 Green Square Close
Fortitude Valley, QLD 4006

Email: Tamara.Bauld@urbanutilities.com.au
Attention: Tamara Bauld

Reference: A-TEL-NEW-100214374

Application for temporary emissions licence (TEL) for flood impacted sewage pump stations at the following sewage pump stations described below.

1 Application details

The application for a temporary emissions licence was received by the administering authority on 2 March 2022.

Application reference number: A-TEL-NEW-100214374

Authorised activity: ERA 63 Sewage treatment (2) operating a sewage pumping station mentioned in subsection (1)(b).

Land description:

- Pump station SP113- Kinloch Street Indooroopilly, Lot 6 Plan RP102749
- Pump station SP322 - 62 Hanlon Street Bundamba, Lot 1 Plan SP230099
- Pump station SP377 - 68 Brisbane Terrace Goodna, Lot 7 Plan SP234916
- Pumps station SP088 – 157 Blackheath road Corrinda, Lot 6 RP95353
- Pump station SP064 - 51 Ortive Street Yeronga, Lot 23 Plan RP37952
- Pump station SP148 - 113 Donaldson Road Rocklea, Lot 19 Plan RP843976
- Pump station SP364 - 47 Boundary Street Moores Pocket, Lot 4 on RP230015
- Pump station SP065 - 55A Stevens Street Yeronga, Lot2 Plan RP118628
- Pump station SP118 - 74 Sandford Street St Lucia, Lot 93 Plan RP40740
- Pump station SP162- 1 Jilba St Indooroopilly, Lot 1 Plan SP100244
- Pump station SP108 - 86A Jarrott St Chelmer, Lot 8, Plan RP187663
- Pump station SP071 - 50 Esplanade Yeronga, Lot 100 Plan CP868497
- Pump station SP050 - 99 Mount Ommaney Drive Jindalee, Lot 1 Plan RP119961
- Pump station SP115 - 2A Turner Street Sherwood, Lot 2 Plan RP125701
- Pump station SP345 - 330 Brisbane Terrace Goodna, Lot 1 Plan RP162110
- Pump station SP063 - 35 Astolat Street Yeronga, Lot 3 Plan SP175544
- Pump station SP083 - NORTH RD WYNNUM WEST, Lot 18 Plan RP213402
- Pump station SP081 - 160 Witton Road Indooroopilly, Lot 57 Plan SL7293
- Pump station SP057 - 2A POMONA ST BRIGHTON, Lot 333, Plan SL8314
- Pump station SP375 - 33 Oxford Street North Booval, Lot 902 Plan SP195478
- Pump station SP023 - 148A EDMONDSTONE ST WILSTON, Lot 2 Plan RP86518
- Pump station SP122 – 37 The Esplanade St Lucia, Lot 2 Plan RP99585
- Pump station SP467 - Linemands Road Lowood, Lot 59 Plan RP854663
- Pump station SP078 - 1938 SANDGATE RD VIRGINIA, Lot 13 Plan RP145534
- Pump station SP055 - 401 STANLEY RD CARINA, Lot 421 Plan SP223110
- Pump station SP344 - 2B Brisbane Road Redbank, Lot 1 Plan RP161486

Decision notice regarding a temporary emissions licence

- Pump station SP343 - 20 McAuliffe Street Redbank, Lot 502 Plan SP231927
- Pump station SP334 - 4 Kenneth Street Riverview, Lot 2 Plan RP164517
- Pump station SP330 - 2 Chalk Street Leichardt, Lot 2 Plan SP208100
- Pump station SP323 - 41A Videroni Street Bundamba, Lot 449 Plan I120725
- Pump station SP254 - 381 Beatty Road Archerfield, Lot 2 Plan SP200283
- Pump station SP312 - 61 BILLAN ST CARINA, Lot 28 Plan RP13175, Lot 29 Plan RP13175, Lot 30 Plan RP13175, Lot 31 Plan RP13175.
- Pump station SP331 - 6 Lobley Street Ipswich, Lot 1 Plan RP199616
- Pump station SP117 – 12 SALTASH ST VIRGINIA, Lot 22 Plan SP236215
- Pump station SP130 – 35 VILLIERS ST TINGALPA, Lot 66 Plan RP32985
- Pump station SP165- AMBARA ST BELMONT, Lot 132 Plan RP143716
- Pump station SP172 - 63 FEUERRIEGEL RD BALD HILLS, Lot 501 Plan RP140769
- Pump station SP352 - 209 Chermside Road East Ipswich, Lot 1 Plan RP66297
- Pump station SP355 - 13 HAIG ST BRASSALL, Lot 6 Plan RP218528
- Pump station SP350- 1 Rosseberry Parade Woodend, Lot 10 Plan SP180876
- Pump station SP320 - 1 Old Toowoomba Road Leichardt, Lot 24 Plan SP185920
- Pump station SP358 - 73 Mount Crosby Road Tivoli, Lot 1 Plan S151814
- Pump station SP374 - 2-34 Junction Road Karalee, Lot 8 Plan SP118670
- Pump station SP016 - 4 Gordon Street Hawthorne, Lot 2 Plan RP56171
- Pump station SP005 - 46 GODWIN ST BULIMBA, Lot 53 Plan RP12532
- Pump station SP044 - 186 LYTTON RD EAST BRISBANE, Lot 286 Plan SL2560
- Pump station SP062 - 36A DEPOT RD DEAGON, Lot 128 Plan SP245843
- Pump station SP072 - 28 ORMUZ RD YERONGA, Lot 92 Plan RP37194
- Pump station SP085 - 32A PRITCHARD ST LYTTON, Lot 516 Plan SL7031
- Pump station SP318 - 112 SUNSET RD KENMORE, Lot 50 Plan SP226147
- Pump station SP336 - 49 Lobb Street Churchill, Lot 1 Plan RP129154
- Pump station SP075 - 110 Kilkivan Ave Kenmore, Lot 45 Plan SP149006
- Pump station SP181 - 22 Sinnamon Road Seventeen Mile Rocks, Lot 60 Plan RP126779
- Pump station SP354 - 3 Boundary Street Moores Pocket, Lot 11 Plan Rp115688
- Pump station SP362 - 166 Moores Pocket Road, Lot 52 Plan RP218484
- Pump station SP357 - 163 Mount Crosby Road North Tivoli, Lot 1 Plan RP215979
- Pump station SP353 - 47B Tiger Street West Ipswich, Lot 1 Plan RP57571
- Pump station SP342 - 33 Moggill Ferry Road Riverview, Lot 2 Plan RP164666
- Pump station SP191 - 160 Gem Road Kenmore, Lot 2 Plan RP113905

Decision notice regarding a temporary emissions licence

- Pump station SP109 - 29 Regatta St Chelmer, Lot 5 Plan SP141283
- Pump station SP116 - 55 Ferry Street Sherwood, Lot 1 Plan M314
- Pump station SP306 - 515A Coronation Drive Towoong
- Pump station SP351 - 1 Tantivity Street Tivoli, Lot 1 Plan SP142073
- Pump station SP127 - 17 Bougainvillea Ave Indooroopilly, lot 39 plan RP84920
- Pump station SP356 - 18A Blackall Street East Ipswich
- Pump station SP232 - 61 Beanland Street Jamboree Heights
- Pump station SP021 - 350 UPPER ESP MANLY, Lot 48 Plan RP33017
- Pump station SP103 - 38B Indooroopilly Road Toowong, Lot 1 RP18765
- Pump station SP335 - 7 Sutton Street Churchill, Lot 61 Plan SP147847
- Pump station SP019 - 303 Centenary Highway Jindalee, Lot 92 Plan RP105603
- Pump station SP042 - 33 BELTANA ST LOTA, Lot 359 Plan RP33228
- Pump station SP073 - 58 Cassia Lane Yeronga, Lot 40 RP84562
- Pump station SP261 - 121 Wendouree Cresent Westlake, Lot 200 Plan RP885583
- Pump station SP178 - 33 Oldfeild road Seventeen Mile Rocks, Lot 1 Plan RP152819
- Pump station SP333 - 113 Ashburn Road Bundamba, Lot 1 Plan RP854996
- Pump station SP086 - 249 Indooroopilly Road Taringa, Lot 131 Plan RP852706
- Pump station SP435 - 23 East Street Boonah, Lot 189 Plan SP238044
- Pump station SP040 – 148A Sunset road, Kenmore, Lot 2 Plan RP113905
- Pump station SP119 – 6A Mcquire Street, St Lucia, Lot 2 Plan RP129611
- Pump station SP209 – 1763 Old Cleveland road Chandler, Lot 1 Plan RP165961
- Pumpstation SP262 – 52 Trade Street Vac Lytton, Lot 10 Plan SP245839
- Pump station SP272 – 55 Greendale Way Carindale, Lot 100 Plan RP907203
- Pump station SP197 – 40 Scenic Road Kenmore, Lot 53 Plan RP109172

2 Decision

In accordance with section 357E(a)(i) of the *Environmental Protection Act 1994*, the administering authority has decided to grant the application as submitted. However, note that the following sewage pump stations are not included in this temporary emissions licence as they are not authorised locations under the EA:

- Pump station SP366 – 168 Woodend Road, Woodend
- Pump station SP380 – 126 Bognuda Street, Bundamba
- Pump Station SP324 – Old Toowoomba Road, Amberley

This temporary emissions licence commences on 3 March 2022 and ends on 3 June 2022.

The licence overrides the following conditions of your environmental authority, approval number EA0001209:

Decision notice regarding a temporary emissions licence

Standard environmental conditions	
Condition number	Condition
10	Release to land and waters The operator must ensure that contaminants are not released to land or waters (including the bed and banks of any waters) as a result of the activity. Condition applies to: SP113, SP088, SP064, SP148, SP065, SP118, SP162, SP108, SP071, SP050, SP115, SP345, SP063, SP083, SP081, SP057, SP023, SP122, SP467, SP078, SP055, SP344, SP343, SP254, SP312, SP117, SP130, SP165, SP172, SP352, SP350, SP016, SP005, SP044, SP062, SP072, SP085, SP318, SP075, SP181, SP354, SP353, SP342, SP191, SP109, SP116, SP306, SP351, SP127, SP232, SP021, SP103, SP019, SP042, SP073, SP261, SP178, SP086, SP435, SP040, SP119, SP209, SP262, SP272, SP197.
11	Notifiable Releases The operator must notify the administering authority via the 24 hour Pollution Hotline or the district office no later than three hours after becoming aware of a sewage release that: (a) poses a threat to public health (for example, contamination of waters with primary recreation values); (b) results in any observable environmental impact (for example, fish kill, distress to wildlife, marine plants or other aquatic life); (c) discharges to, or is likely to impact, a sensitive environment (for example, Ramsar wetland, marine park, or area designated as a conservation zone under a relevant planning scheme); or (d) is 10 000 L or more during dry weather. Condition applies to all pump stations listed in the land description above.
12	Notifiable Releases Within 24 hours after becoming aware of a notifiable release in accordance with condition 11, email or written notification of the release must be submitted to the administering authority outlining the event, its nature and the circumstances in which it happened. Condition applies to all pump stations listed in the land description above.
13	Notifiable releases A final report must be provided to the administering authority within 14 business days of the conclusion of the spill response and remediation of a notifiable release, but no later than 20 business days after the commencement of the release. Condition applies to all pump stations listed in the land description above.

Notice

Decision notice regarding a temporary emissions licence

24	Responding to potential releases The operator must ensure that there are appropriate physical systems in place to anticipate a potential release. Condition applies to: SP113, SP088, SP064, SP148, SP065, SP118, SP162, SP108, SP071, SP050, SP115, SP345, SP063, SP083, SP081, SP057, SP023, SP122, SP078, SP055, SP344, SP343, SP254, SP312, SP117, SP130, SP165, SP172, SP352, SP350, SP016, SP005, SP044, SP062, SP072, SP085, SP318, SP075, SP181, SP354, SP353, SP342, SP191, SP109, SP116, SP306, SP351, SP127, SP232, SP021, SP103, SP019, SP042, SP073, SP261, SP178, SP086, SP040, SP119, SP209, SP262, SP272, SP197, SP320, SP323, SP322, SP330, SP331, SP333, SP334, SP335, SP336, SP355, SP356, SP357, SP358, SP362, SP364, SP374, SP375, SP377.
25	Responding to potential releases Any system developed in line with condition 24 must be able to operate for a sufficient time to allow for notification of the potential release to the operator and an appropriate response. Condition applies to all pump stations listed in the land description above.
26	Responding to potential releases Any identification of a potential release must be responded to by the operator. Condition applies to all pump stations listed in the land description above.

Varied Conditions			
Condition number	Condition	Sites that varied condition applies to	
		Site name	Lot on plan
10	Release to land and waters The operator must ensure that contaminants are not released to land or waters (including the bed and banks of any waters) as a result of the activity. The only exception to this condition is that a sewage release to land or waters (including the bed and banks or any waters) may occur as a result of the activity only when all of the following apply: (a) the release is as a result of a wet weather event; and (b) the hydraulic flow into the sewage pump station exceeds the peak design capacity of the sewage pump(s) at the time the contaminants are released; and (c) all reasonable and practicable measures have been taken to prevent the release; and	SP320 1 Old Toowoomba Road, LEICHHARDT	Lot 24 Plan SP185920
		SP322 62 Hanlon Street, BUNDAMBA	Lot 1 Plan SP230099
		SP323 Videroni Street, SILKSTONE	Lot 449 Plan I120725
		SP330 2 Chalk Street, LEICHHARDT	Lot 2 Plan SP208100
		SP331 6 Lobley Street, IPSWICH	Lot 1 Plan RP199619
		SP333 113 Ashburn Road, BUNDAMBA	Lot 1 Plan RP854996
		SP334 81 Riverview Road, RIVERVIEW	Lot 2 Plan RP164517
		SP335 7 Sutton Street, CHURCHILL	Lot 61 Plan SP147847
		SP336 49 Lobb Street, CHURCHILL	Lot 1 Plan RP129154

Decision notice regarding a temporary emissions licence

	(d) the administering authority has been notified in accordance with condition 11.		
		SP355 Mihi Junction Reserve, Collins Street, BRASSALL	Lot 6 Plan RP218528
		SP356 18a Blackall Street, EAST IPSWICH	Lot 1 Plan SP230093
		SP357 163 Mount Crosby Road, NORTH TIVOLI	Lot 1 Plan RP215979
		SP358 73 Mount Crosby Road, TIVOLI	Lot 1 Plan S151814
		SP362 Moores Pocket Road, MOORES POCKET	Lot 52 Plan RP218481
		SP364 47 Boundary St, MOORE POCKET	Lot 4 Plan RP230015
		SP374 2-34 Junction Road, KARALEE	Lot 8 Plan SP118670
		SP375 33 Oxford Street, NORTH BOOVAL	Lot 902 Plan SP195478
		SP377 68 Brisbane Terrace, GOODNA	Lot 7 Plan SP234916
24	Responding to potential releases By 1 January 2017, the operator must ensure that there are appropriate physical systems in place to anticipate potential releases from all sewage pumping stations to which this authority relates.	SP467 Lindemans Road, LOWOOD	Lot 59 Plan RP854663
24	Responding to potential releases By 20/11/2016, the operator must ensure that there are appropriate physical systems in place to anticipate a potential release.	SP435 Elliott Road, BOONAH 4210	Lot 189 Plan SP238044

2.1 Temporary Emissions Licence Conditions

The following conditions temporarily apply to the locations as described above on this licence:

Decision notice regarding a temporary emissions licence

Condition number	Condition
TEL-1	Release to land and waters The operator must ensure that contaminants are not released to land or waters (including the bed and banks of any waters) as a result of the activity. The only exception to this condition is that a sewage release to land or waters (including the bed and banks or any waters) may occur as a result of the activity only when the following apply: (a) the release is as a result of a wet weather event; or (b) the following has occurred: (i) hydraulic flow into the sewage pump station exceeds the peak design capacity of the sewage pump(s) at the time the contaminants are released; or (ii) the sewage pump station is not operational due to power failure, inundation, or critical impacts due to flooding; or (iii) the sewage pump station is not operational due to critical component being removed to protect the asset or is connected to a resource recovery centre that is unable to receive flows due to power failure or critical impacts due to flooding; and (c) all reasonable and practicable measures have been taken to prevent the release; and (d) the administering authority has been notified in accordance with condition TEL-2 of this temporary emissions licence (TEL).
TEL-2	The operator must provide the administering authority's Pollution Hotline with weekly notification reports (commencing from 7 March 2022) advising of the following for any sewage pump station surcharges or releases to the environment: (a) number of pump stations actively surcharging and/or releasing; and (b) anticipated pump station recovery actions and associated timeframes; (c) results from monitoring of releases.
TEL-3	For releases that have been notified to the administering authority under condition TEL-2, a final report must be provided to the administering authority by 14 business days from the conclusion of this TEL, summarising: (a) the surcharge and release response actions; and (b) any remediation activities that have occurred and are yet to occur.
TEL-4	Conditions 24 and 25 (whether varied conditions or standard conditions) of environmental authority EA0001209 do not apply in the following circumstances: (a) A sewage pump station has been switched off to protect the asset; or (b) A sewage pump station has no power.
TEL-5	Any release of sewage from a pump station must be responded by the operator in a reasonable timeframe where it is practicable to do so. <i>Note: An example of a response not being practicable may include:</i> (a) <i>safety being compromised; or</i> (b) <i>resources are required to be diverted elsewhere due to public health or environmental protection priorities.</i>

Decision notice regarding a temporary emissions licence

Should you have any queries in relation to this notice, Liz Clarke, Manager, on telephone 0402 968 411 would be happy to assist you.



Signature

3 March 2022

Date

Liz Clarke
Department of Environment and Science
Delegate of the administering authority
Environmental Protection Act 1994

Enquiries:

Utilities and Government Organisations
Assessment

Phone: 1300 130 372

Email:

industryanddevelopment.assessment@des.qld.gov
.au