

Notice

Environmental Protection Act 1994

Notice of decision - Temporary emissions licence

This statutory notice is issued by the administering authority pursuant to section 357E of the Environmental Protection Act 1994, to advise you of a decision or action.

To: Central SEQ Distributor – Retailer Authority
Queensland Urban Utilities
GPO Box 2765
BRISBANE, QLD 4001

Email: tamara.bauld@urbanutilities.com.au
Attention: Tamara Bauld

Our reference: ENEL05986914

Application for temporary emissions licence (TEL) for releasing of partially treated sewage from Oxley Sewage Treatment Plant at 240 Donaldson Road, ROCKLEA, QLD 4106 to waters from discharge points W1 and W2.

Thank you for your application for a temporary emissions licence. Your application, which was received by this office on 28-NOV-2014, has been granted as submitted.

This temporary emissions licence commences on 28-NOV-2014 and ends on 9-JAN-2015 or earlier as stated in condition 1 of this temporary emissions licence.

The licence permits the following emission:

- The release of partially treated sewage from the Oxley Sewage Treatment Plant to waters from discharge points W1 and W2.

The licence overrides the following conditions of your environmental authority, approval number EPPR00521513 (formerly known as SR0461DA):

- Conditions C1, C2, C4 and C19-1

The following conditions apply to this licence:

1. If the release process ends before 9 January 2015, this temporary emissions licence ceases to have effect on the day the release process ends.
2. The holder of this temporary emissions licence must monitor the following parameters, at the locations, and at the frequency specified in the following table until such time as the temporary emissions licence ends:

Parameter	Monitoring to commence	Frequency	Location
BOD5 (mg/L)	Immediately once any release of raw sewage commences	Daily for the first two (2) weeks and then twice weekly thereafter whilst discharge is occurring	Discharge points W1 and W2
Suspended Solids (mg/L)	Immediately once any release of raw sewage commences	Daily for the first two (2) weeks and then twice weekly thereafter whilst discharge is occurring	
Total Nitrogen (mg/L)	Immediately once any release of raw sewage commences	Daily for the first two (2) weeks and then twice weekly thereafter whilst discharge is occurring	

Decision notice regarding a temporary emissions licence

Total Phosphorous (mg/L)	Immediately once any release of raw sewage commences	Daily for the first two (2) weeks and then twice weekly thereafter whilst discharge is occurring	
pH (pH units)	Immediately once any release of raw sewage commences	Daily for the first two (2) weeks and then twice weekly thereafter whilst discharge is occurring	
Dissolved Oxygen (mg/L)	Immediately once any release of raw sewage commences	Daily for the first two (2) weeks and then twice weekly thereafter whilst discharge is occurring	
Faecal Coliforms (organisms/100mL)	Immediately once any release of raw sewage commences	Daily for the first two (2) weeks and then twice weekly thereafter whilst discharge is occurring	
Volume (L)	Immediately once any release of raw sewage commences	Continuous	

3. The holder of this temporary emissions licence must:
- Keep all monitoring data for a period of not less than 5 years and provide to the administering authority upon request;
 - Notify the administering authority once the release process ceases.

Should you have any queries in relation to this notice, Dot Rosiak on telephone (07) 3330 6372 would be happy to assist you.



Signature



Date

Chris Mooney
Department of Environment and Heritage Protection
Delegate of the administering authority
Environmental Protection Act 1994

Enquiries:
Dot Rosiak
Industry and Development Assessment
PO Box 2454
Level 8, 400 George Street
BRISBANE QLD 4001
Phone: (07) 3330 6372
Fax: (07) 3330 5875
Email: Dorota.Rosiak@ehp.qld.gov.au