# Notice

***Environmental Protection Act 1994***

## Notice of decision - Temporary emissions licence

*This statutory notice is issued by the administering authority pursuant to section 357E and 357F of the* Environmental Protection Act 1994*, to advise you of a decision or action.*

To: Cedar Lake Country Club Limited
C/- Simmonds & Bristow
2A 40 Reginald St
ROCKLEA QLD 4106

Email:david@simmondsbristow.com.au
Attention: David Bristow

Your reference: EPPR00579313 / IPDE00105305A11
Our reference: 251857

**Application for temporary emissions licence (TEL) for continued irrigation of effluent with possible erosion and runoff of effluent at 555 Nerang Murwillumbah Road, ADVANCETOWN; Lot 3 on Plan RP134048.**

Thank you for your application for a temporary emissions licence. Your application, which was received by this office on 29 March 2017 at 4.25pm, has been granted on different terms than those requested.

This Temporary Emissions Licence (TEL) commences on 30 March 2017 and ends on 05 April 2017.

1. **Licence conditions overridden:**
   The TEL overrides the following conditions of your environmental authority, approval number EPPR00579313:

   *Water 1: Contaminants must not be released from the site to any waters or the bed or banks of any waters except as otherwise provided by the conditions of this development approval.*

   *Land 1: The only contaminants permitted to be released to land are treated sewage effluent from ponds #2 and #5 to Site 1 shown in Attachment 1 – Cedar Lake Country Resort Site Layout in compliance with the limits stated in Table 1 – Contaminant release limits to land.*

   *Land 5: The irrigation of effluent must be carried out in a manner such that: (c) there is no surface ponding or runoff of effluent.*

2. **Conditions of TEL:**
   The TEL is granted subject to the following conditions:

1. Only the following volumes of treated effluent are permitted to be irrigated evenly over Site 1 under the following conditions:

   a. Irrigation of a maximum of 4mm/day (120 $m^3$/day) during rainfall of >5mm/day;

   b. Irrigation of a maximum of 1.7mm/day (50$m^3$/day) in the 2 days following rain of >5mm/day.



ABN 46 640 294 485

2. The only surface ponding or runoff of treated effluent permitted is that resulting from the irrigation of treated effluent under Condition 1 of the TEL.

3. The only contaminant permitted to be released to land is treated effluent relating to Conditions 1 and 2 of the TEL.

4. The only contaminant permitted to be released to waters is treated effluent relating to Conditions 1 and 2 of the TEL.

5. Appropriate monitoring of the treated effluent quality must be undertaken at the beginning and end of the irrigation under Condition 1 of the TEL.

6. Department of Environment and Heritage Protection (EHP) must be notified of the commencement of irrigation under Condition 1 of the TEL as soon as practical, but no later than 6 hours after commencement of irrigation. The notification must be to the **Pollution Hotline** via phone on **1300 130 372** or email pollutionhotline@ehp.qld.gov.au.

7. EHP must also be notified within 6 hours of cessation of irrigation under Condition 1 of the TEL using the contact details in condition 6.

8. EHP must be immediately notified of any incident, or environmental impact from the release, that was not foreseen when making application for this TEL.

9. All reasonable and practicable measures must be taken to prevent or minimise environmental harm caused as a result of this TEL.


10. All records must be kept for a period of at least five years and provided to the administering authority upon request.

11. Notwithstanding any condition of this TEL, if the release of contaminated water causes adverse impact on an environmental value of the receiving environment, the holder of this TEL must take appropriate action/s to remedy the situation.

### 3. Grounds for granting on different terms than those requested:

The administering authority had concerns that conditions in addition to that identified in the application would not be complied with, with the proposed release (Water 1 and Land 1). As such, these conditions were included on the TEL allowing them to be overridden subject to compliance with the above conditions.

Should you have any queries in relation to this notice, Lisa Fritz on telephone 4529 8329 would be happy to assist you.




Signature

Date

Tariq Khan
Department of Environment and Heritage Protection
Delegate of the administering authority
*Environmental Protection Act 1994*

**Enquiries:**
Industry & Development Assessment
Phone: 4529 8329
Fax: 4529 8388
Email: Lisa.Fritz@ehp.qld.gov.au